



End User Notes:
 The "EFL" is furnished without wiring.
 All wiring shall be made by others.
 All wiring between the Actuator and
 the "EFL" shall be contained in Flexible
 or Rigid Conduit or as required by
 the applicable Fire and/or Electrical
 Codes.

A	Add Alternate EMB SPDT Switch	5/1/03	M.R
No:	Revision	Date	Chk'd by:
Globe "EFL" Electrical Schematic GLOBE TECHNOLOGIES CORP. 1109 W. CEDAR ST. STANDISH, MI 48658			
Scale: N/A	Chk'd by: <i>M.R.</i>	Dwg: 1 of 1	eflect.dwg